

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-1335:108 Page 1 of 1

CATEGORY: Power Units

LISTEE: Altronix Corp., 140 - 58th Street, Building A-3W, Brooklyn NY 11220
Contact: Alan Forman (718) 567-8181 Fax (718) 567-9056

DESIGN: Model RAB2 Polarity Reversing Relay Module. Unit reverses the polarity of input power when one of the smoke detectors goes into alarm, allowing all the smoke detectors in the loop to sound. It is triggered by the control panel's pulsing bell output or alarm relay contact. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 8.5 to 35 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as relay module for use with separately listed compatible 2-wire and/or 4-wire smoke detector.

10-29-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**